

# Invisible **Structures' Memo**



Date: 7-28-08  
To: Kevin Cobaugh  
From: Kate Wright  
Re: Geogrid use in a Rainstore3 chamber

Kevin,

This memo is regarding the use of geogrid in a Rainstore3 chamber. Our specification calls for the Tensar BX 1200 or equivalent for all three layers in a Rainstore3 chamber. The following geogrids are considered equivalents and are acceptable for use with our system:

Mirafi BasXGrid 12  
Secugrid 30/30-Q1  
Tenax MS 330  
Terragrid B120  
Synteen SF12

Please contact me directly if you have any questions – 303-395-1809.

Thanks,  
Kate Wright  
Staff Engineer

Invisible Structures, Inc. • [www.invisiblestructures.com](http://www.invisiblestructures.com)  
1600 Jackson St., Suite 310 • Golden, Colorado 80401  
USA/Canada Toll-Free Ph: 800-233-1510 Fax; 800-233-1522  
Local and Overseas Ph: (USA)303-233-8383 Fax: (USA)303-233-8282